

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 6911-1429:113 Page 1 of 1

CATEGORY: Voice Communication System Control Unit

LISTEE: Secutron Inc., 70 Esna Park Dr., Unit 14, Markham, Ontario, Canada L3R 6E7
Contact: *Paul Mattern (978) 731-8542

DESIGN: Models MV-2700M and MV-2700D audio adjunct/voice evacuation systems. The MV-2700M is the master panel in the system while the MV-2700D is the distributed panel. Each system is modular in construction. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

PWR-2A	Power Supply
MFP	Master Fire Phone Card
DCC	Data Communication Control Card
ASC	Audio System Control Card
SSC	Switch Scan Card
MMC	Microphone Master Control Card
IOI	Input/Output Card
SLC	Switch and LED Card
MFH	Master Fire Phone Handset Card
MBR	Motherboard Card
AMI	Audio Module Interface Card
FPI	Fire Phone Interface Card
MBK	Motherboard/Relay Card

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as voice communication/evacuation/relocation/paging system for use with Evax's Models EVX-25 (CSFM Listing No. 6911-1446:100) or EVX-50 (CSFM Listing No. 6911-1446:102) and separately listed electrically compatible fire alarm control unit.

XLF: 6911-1446:103

*Rev. 09-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

SEPTEMBER 12, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager